

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Annual Periodical Renewal Fire Certificate

From:
 Regional Fire Officer
 Andhra Pradesh, Vijayawada

To:
 Jawaharlal Nehru Technical University,
 Kakinada, Andhra Pradesh

File No: 15910/GNT/RFO/2020, Date:20/02/2021

Occupancy NoC RC Number: 10847/GNT/RFO/2019

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **Tirumala Engineering College under Venkata Ramana Charitable Trust, represented by R Satyannarayana, D.No. 296/B, 294/A, 295/B, 294/B1, 295/C1, 296/C, 294/B1, 295/C1, 294/B1, 294/A, 295/B, 295/C1, 294/A, 295/B, 295/A, 296/A, Guntur Road, Jonnalagadda, Grama Panchayat, Narasaraopet Mandal, Guntur District - Regarding.**

- Ref:
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
 3. This Office NOC for Occupancy Rc No. 10847/GNT/RFO/2019, Dt.19/12/2019
 4. Renewal NOC For Occupancy 10847/GNT/RFO/2019, Dt.19/12/2019
 5. Online Application for Renewal NOC of R Satyannarayana, D.No. 296/B, 294/A, 295/B, 294/B1, 295/C1, 296/C, 294/B1, 295/C1, 294/B1, 294/A, 295/B, 295/C1, 294/A, 295/B, 295/A, 296/A, Guntur Road, Jonnalagadda, Grama Panchayat, Narasaraopet Mandal, Guntur District - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 01-02-2021.

<< 0 >>

The Management of Tirumala Engineering College under Venkata Ramana Charitable Trust, represented by R Satyannarayana, D.No. 296/B, 294/A, 295/B, 294/B1, 295/C1, 296/C, 294/B1, 295/C1, 294/B1, 294/A, 295/B, 295/C1, 294/A, 295/B, 295/A, 296/A, Guntur Road, Jonnalagadda, Grama Panchayat, Narasaraopet Mandal, Guntur District has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.334900/- vide challan No. 41286320652020, Dated 19/12/2020 at SBI, Online Payment.

Tirumala Engineering College under Venkata Ramana Charitable Trust

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate R Satyannarayana D.No. 296/B, 294/A, 295/B, 294/B1, 295/C1, 296/C, 294/B1, 295/C1, 294/B1, 294/A, 295/B, 295/C1, 294/A, 295/B, 295/A, 296/A, Guntur Road, Jonnalagadda, Grama Panchayat, Narasaraopet Mandal, Guntur District, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 19/12/2020 to 18/12/2025.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

Conditions :

☐ This Renewal NOC is issued form Fire Safety Point of view only basing on recommendation of the Guntur District Inspection committee of DFO & ADFO & SFO Narasaraopet only and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.

☐ The Management has to maintain Fire Safety Measures and other installations in good working condition at all times and the Responsibility of Fire Fighting equipment maintenance lies with the management as seen & tested by the committee at the time of inspection.

☐ The life safety and neighbor safety risk to be borne by the Management only. This Certificate covers Fire Safety Equipment installation as per NBC-2106. The Legal issue in respect of life safety doesn't cover under this Certificate. The Management is responsible all risks involved in case of Fire Accident in the Building

☐ This Renewal NOC is valid for (05) years only and It is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per G.O.Ms.No.140, Home (Prisons & Fire Service) Department.Dt.04-09-2015, two months before expire of this No Objection Certificate and shall provide the deficit firefighting equipment as per NBC within (06) months



15910/GNT/RF0/2020

Your Sincerely,

Regional Fire Officer
Andhra Pradesh, Vijayawada

Copy to R Satyannarayana, R Satyannarayana, Guntur Road, Jonnalagadda, Grama Panchayat, Narasaraopet Mandal, Guntur District

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

